

CERTIFICATE OF COMPLIANCE

Certificate Number E196811
Report Reference E196811-20181231
Date 2023-July-04

Issued to: PHOENIX CONTACT GmbH & Co. KG
Flachsmarktstrasse 8
Blomberg Nordrhein-Westfalen, 32825 DE

This is to certify that representative samples of PROGRAMMABLE CONTROLLERS FOR USE IN
HAZARDOUS LOCATIONS
See Addendum Page for Product Designation(s).

Have been evaluated by UL in accordance with the
Standard(s) indicated on this Certificate.


Standard(s) for Safety: See Addendum Page for Standard(s)

Additional Information: See the UL Online Certifications Directory at
<https://iq.ulprospector.com> for additional information

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.


Deborah Jennings-Conner, VP Regulatory Services
UL LLC



Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

CERTIFICATE OF COMPLIANCE

Certificate Number E196811
Report Reference E196811-20181231
Date 2023-July-04

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements

Class I, Division 2, Groups A, B, C & D Hazardous Locations.

Axio P

Models AXL P BK followed by PN, ETH, EIP, HSE, or UNI, may be preceded or followed by xxx which can indicate any number or combination of alphanumeric characters to indicate customer-specific models, may also be followed by AF or EF; AXL P FBPS 28DC/0.5A; AXL P FBPS BASE; AXL P DI16 NAM 1F; AXL P DI16/2 1F; AXL P AI8 HART 1F; AXL P AI8 P HART 1F; AXL P AO4 HART 1F; AXL P RTD8 1F

Accessories for use with above models:
AXL P TERM PAIR

Axio F

Models AXL F DI16 NAM XC 1F; AXL F AI8 HART XC 1F; AXL F AI8 P HART XC 1F; AXL F AO4 HART XC 1F

Standard(s):

UL 121201, Nonincendive Electrical Equipment for Use in Class I and II, Division 2 and Class III, Divisions 1 and 2 Hazardous (Classified) Locations;
CAN/CSA C22.2 No. 213-17, Nonincendive Electrical Equipment for Use in Class I and II, Division 2 and Class III, Divisions 1 and 2 Hazardous (Classified) Locations.

Deborah Jennings-Conner

Deborah Jennings-Conner, VP Regulatory Services

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

