



CERTIFICATION REPORT

Moncton ■ Montréal ■ Toronto ■ Winnipeg ■ Edmonton ■ Vancouver ■ Brussels ■ Taiwan ■ Hong Kong

MASTER REPORT NO: LR 13631-203

Edition 1: June 29, 1992; Application No LR 13631-203 - Rexdale
Issued by P. Johnson, C.E.T.; Reviewed by D. Hay, P. Eng.

Edition 2: August 30, 1993; Application No LR 13631-261 - Rexdale
Issued by J. DaSilva, C.E.T.; Reviewed by D. Hay, P. Eng.

Pages Replaced: Report Re-Issued

Contents: Pages - 1 to 4
Figures - Fig 1

SUBJECT

CLASS 6228 01 - WIRE CONNECTING DEVICES - Terminal Assemblies

Terminal blocks, Cat No SMKDSP1.5/X and SMKDSP1.5/X-5.08, rated 300V, 10A, for use with solid or stranded copper wire, Nos 28 to 14 AWG.

Notes:

1. These terminal blocks are Certified, as components, for use only in Certified equipment where the suitability of the combination is determined by the Canadian Standards Association.
2. Suffix 'X' denotes number of positions.