



Certificate of Compliance

Certificate: 1941560 **Master Contract:** 158887
Project: 80112690 **Date Issued:** 01/30/2023
Issued to: PHOENIX CONTACT GmbH & Co. KG
Flachsmarkstraße 8
Blomberg, North Rhine-Westphalia D-32825
Germany
Attention: Oliver Pethig

The products listed below are eligible to bear the CSA Mark shown



Issued by: Manikandan N
Manikandan N

PRODUCTS

C622801 WIRE CONNECTING DEVICES - Terminal Assemblies

Terminal blocks, Screw type connection, for solid and stranded copper insulated conductors as follows:

Models	Wire Range (AWG)	Torque (N · m)	Voltage (V)	Current (A)	Use Group
MK3DS3X/-5.08	28-12	0.5-0.6	300	10	B, D
MK3DS3/18-36-5.08	28-12	0.5-0.6	300	10	B, D
MK3DS3/18-52-5.08	28-12	0.5-0.6	300	10	B, D



Certificate: 1941560

Project: 80112690

Master Contract: 158887

Date Issued: 01/30/2023

APPLICABLE REQUIREMENTS

CSA C22.2 No. 158:10 (R2019) - Terminal Blocks



Certificate: 1941560

Project: 80112690

Master Contract: 158887

Date Issued: 01/30/2023

Notes:

Products certified under Class C622801 have been certified under CSA's ISO/IEC 17065 accreditation with the Standards Council of Canada (SCC). www.scc.ca

