



Certificate of Compliance

Certificate Number: LR 13631-79

Revision: LR 13631-312

Date Issued: March 1, 1995

Issued To: Phoenix Contact Inc.
P.O. Box 4100
Harrisburg, PA 17111
USA

The products listed below are eligible to bear the CSA Mark.

Issued By: S. Clark, C.E.T.
Toronto, ON Canada

Signature

CLASS 6228 01 WIRE CONNECTING DEVICES - Terminal Assemblies

PRODUCTS

Terminal blocks for use with CSA Certified solid and stranded copper conductors Series MKDS 1/X-3.81 and MKDS 1/X-3.81 SMD BK rated 10A, 150/300V, 2.5 lbs-in torque with Nos 28-16 AWG conductors and Series MKDSN 1.5/X, MKDSN 1.5/X-5.08, MKDSNB 1.5/X and MKDSNB 1.5/X-5.08 rated 10A, 150/300V, 2.5 lbs-in torque with Nos 28-14 AWG conductors; GMKDSN1.5/X-7.62 rated 10A, 300V, 2.5 lbs-in torque with Nos 28-14 AWG conductors; Cat No MKDS1/X-3.5, rated 150/300V, 10A, for use with solid or stranded Nos 28 to 16 AWG copper wire.

APPLICABLE REQUIREMENTS

CSA Std C22.2 No. 158-1987 - Terminal Blocks