



Certificate of Compliance

Certificate: 70042859 (LR 13631)

Master Contract: 158887

Project: 70042859

Date Issued: 2015-10-20

Issued to: Phoenix Contact GmbH & Co. KG
8 Flachsmarktstrasse
Bloomberg, D-32825
Germany

Attention: Paul Bastel

The products listed below are eligible to bear the CSA Mark shown



Issued by: *Johann Borabon*
Johann Borabon

PRODUCTS

CLASS 6228 01 - WIRE CONNECTING DEVICES-Terminal Assemblies

Terminal block Series AKG 35 with suffixes, bus bar type, rated 135A, 3.7 N-m torque, for use with Nos 18-2 AWG solid and stranded copper conductor.

Terminal block Series AKG 16 with suffixes, bus bar type, rated 65A, 3.3 N-m torque, for use with Nos 18-6 AWG solid and stranded copper conductor.

Terminal block Series AKG 4 with suffixes, bus bar type, rated 20A, 1.8 N-m torque, for use with Nos 22-12 AWG solid and stranded copper conductor.

Note: Series AKG 35, AKG 16, AKG 4 may be followed by suffixes "BK" and "GNYE".

APPLICABLE REQUIREMENTS

CSA Std. C22.2 No. 158-10 - Terminal Blocks



Supplement to Certificate of Compliance

Certificate: 70042859 (LR 13631)

Master Contract: 158887

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
70042859	2015-10-20	Consolidation of reports LR 13631-86 and -76 and add Series AKG 4 (BK and GNYE).