



Certificate of Compliance

Certificate: 2492418 (LR 13631)

Master Contract: 158887

Project: 2492418

Date Issued: March 15, 2012

Issued to: Phoenix Contact Inc.

P.O. Box 4100
Harrisburg, PA 17111-0100
USA
Attention: Brian Fleming

The products listed below are eligible to bear the CSA Mark shown



Minoru Morimoto

Issued by: Minoru Morimoto, C.E.T.

PRODUCTS

CLASS 6228 01 - WIRE CONNECTING DEVICES - Terminal Assemblies

Grounding terminal blocks, Cat No USLKG 5, USLKG5-1, for No 26 to 10 AWG (torque 6.2 in-lb); Cat No USLKG 3, USLKG3-1, for No 22 to 12 AWG (torque 6.2 in-lb); Cat No USLKG 16N, USLKG16N-1, for No 22 to 4 AWG (torque 20.0 in-lb); Cat No UK 3-RETURN-PE, for No 22 to 12 AWG (torque 5.0 in-lb); Cat No UK-FRONT 4-PE, for No 24 to 10 AWG (torque 6.5 in-lb); USLKG2.5-1, USLKG4-1, USLKG10-1, USLKG16-1, USLKG35-1, for solid and stranded copper conductors.

Note: These products are certified only for supply to manufacturers for the assembly as components of equipment where the suitability of the combination is determined by CSA International.

APPLICABLE REQUIREMENTS

CSA Standard C22.2 No. 158 - Terminal Blocks