

CERTIFICATE

Issued to:
Applicant:
Phoenix Contact GmbH & Co. KG
Flachmarktstrasse 8
32825 Blomberg, Germany

Licensee:
Phoenix Contact GmbH & Co. KG
Flachmarktstrasse 8
32825 Blomberg, Germany

Product : Terminal blocks
Trade name(s) : Phoenix Contact
Type(s)/model(s) : USLKG 2,5N and USLKG 3

The product and any acceptable variation thereto as specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to EN 60947-7-2:2009
- an inspection of the factory location according to CENELEC Operational Document CIG 021
- a DEKRA certification agreement with the number 900469

DEKRA hereby grants the right to use the KEMA-KEUR certification mark.

The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration and under the conditions of the KEMA-KEUR certification agreement.

This certificate is issued on 20 September 2023 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 71-130411

DEKRA Certification B.V.



B.T.M. Holtus
Managing Director



H.R.M. Barends
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE
DUTCH ACCREDITATION
COUNCIL



SPECIFICATION OF THE CERTIFIED PRODUCT**Product data**

Product	: Terminal blocks
Trade name(s)	: Phoenix Contact
Type(s)/model(s)	: USLKG 2,5N and USLKG 3
Material	: thermoplastic material
Mounting	: top hat rail 35 mm and G-profile rail 32 mm

Product data – type USLKG 2,5N

Rated connection capacity	: 2,5 mm ²
Connectable conductors	: one conductor 0,2 - 4 mm ² solid 0,2 - 2,5 mm ² flexible without ferrule 0,25 - 2,5 mm ² flexible with ferrule two conductors 0,2 - 1,0 mm ² solid 0,2 - 1,0 mm ² flexible without ferrule 0,25 - 1,5 mm ² flexible with ferrule
Description	: protective conductor terminal block with 2 screw-type clamping units, 1-pole

Product data – type USLKG 3

Rated connection capacity	: 2,5 mm ²
Connectable conductors	: one conductor 0,2 - 4 mm ² solid 0,2 - 2,5 mm ² flexible without ferrule 0,25 - 2,5 mm ² flexible with ferrule two conductors 0,2 - 1,5 mm ² solid 0,2 - 1,5 mm ² flexible without ferrule 0,25 - 1,5 mm ² flexible with ferrule
Description	: protective conductor terminal block with 2 screw-type clamping units, 1-pole

TESTS**Test requirements**

EN 60947-7-2:2009

Test result

The test results are laid down in DEKRA test file 227782200.

Additional information

This certificate replaces certificate No. 71-102499 which we hereby declare invalid.

Conclusion

The examination proved that all requirements were met.

Factory locations

The factory locations are registered with the numbers 676000, 306086, 330626, 296866, 296864, 326192, 32170, 33937, 36852 and 55519.