



Certificate of Compliance

Certificate Number: LR13631-356


Revision:

Date Issued: February 21, 1997

Issued to: Phoenix Contact Inc.
P.O. Box 4100
Harrisburg, PA 17111 U.S.A
Attention: Mr. Kurt Boegli

The products listed below are eligible to bear the CSA Mark

Issued by: T. Hamden
Toronto, ON Canada

Signature: 

CLASS 6228 01 - WIRE CONNECTING DEVICES - Terminal Assemblies

PRODUCTS

Terminal block, Cat No USLK 2.5N, "Grounding Type" for Nos 28-12 AWG solid and stranded copper conductors, 6.2 lb-in.

APPLICABLE STANDARDS

CSA Std C22.2 No.	0.4-M1982	- Bonding and Grounding of Electrical Equipment (Protective Grounding)
CSA Std C22.2 No.	158-1987	- Terminal Blocks



Supplement to Certificate of Compliance

Certificate Number: LR13631-356

Issued to: Phoenix Contact Inc.
P.O. Box 4100
Harrisburg, PA 17111 U.S.A
Mr. Kurt Boegli

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Issued By: T. Hamden
Toronto, ON Canada

Signature

Product Certification History

Revision	Date	Description
LR13631-356	February 21, 1997	Original Certification



Descriptive and Test Report


Montréal ■ Toronto ■ Edmonton ■ Vancouver ■ Tokyo ■ Hong Kong

REPORT NO: LR13631-356

Edition 1: February 21, 1997; Application No LR13631-356 - Etobicoke
Issued by T. Hamden

Contents: Pages - 1 to 4
Figures - 1

**Universal Ground
Terminal Blocks
USLKG**



USLKG 2,5 N

Terminal width 5.2

Type

USLKG 2,5 N

Order No.

04 41 11 9

Pcs.
Pkt.

50

Dimensions

Width / length

Height (NS 35:7.5 / NS 35:15 / NS 32)

(mm) 6.2 / 42.5

(mm) 47 / 54.5 / 52

FIG. 1 LR 13631-356