



Certificate of Compliance

Certificate Number: LR 13631-106

Revision: LR 13631-283

Date Issued: August 10, 1994

Issued To: PHOENIX CONTACT INC.
P.O. Box 4100
Harrisburg, PA 17111

The products listed below are eligible to bear the CSA Mark.

Issued By: P. Johnson, C.E.T.
Toronto, ON Canada

Signature

CLASS 6228 01 - WIRE CONNECTING DEVICES - Terminal Assemblies

PRODUCTS

Grounding terminal blocks; Cat No USLKG 5, for No 18 to 10 AWG (torque 6.2 in-lb), Cat No USLKG 3, for No 22 to 12 AWG (torque 6.2 in-lb), Cat No USLKG 16N, for No 22 to 4 AWG (torque 20.0 in-lb), Cat No UK 3-RETURN-PE, for No 22 to 12 AWG (torque 5.0 in-lb), and Cat No UK-FRONT 4-PE, for No 24 to 10 AWG (torque 6.5 in-lb), USLKG2.5-1, USLKG3-1, USLKG4-1, USLKG5-1, USLKG10-1, USLKG16-1, USLKG16N-1, USLKG35-1, for solid and stranded copper conductors.

APPLICABLE REQUIREMENTS

CSA Std C22.2 No. 158-1987 - Terminal Blocks