

CERTIFICATE

Issued to:

Applicant:

PHOENIX CONTACT GmbH & Co. KG
Flachsmarktstrasse 8
32825 Blomberg, Germany

Licensee:

PHOENIX CONTACT GmbH & Co. KG
Flachsmarktstrasse 8
32825 Blomberg, Germany

Product : TERMINAL BLOCKS
 Trade name(s) : PHOENIX CONTACT
 Type(s)/model(s) : URTK/S, URTK/S-BEN, URTK/S-BEN BU and URTK/SP

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard EN 60947-7-1:2009
- an inspection of the production location according to CENELEC Operational Document CIG 021
- a certification agreement with the number 900469

DEKRA hereby grants the right to use the KEMA-KEUR certification mark.

The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration of the KEMA-KEUR certification agreement and under the conditions of the KEMA-KEUR certification agreement.

This certificate is issued on 17 January 2018 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 71-102522

DEKRA Certification B.V.



drs. G.J. Zoetbrood
 Managing Director



Jens Marggraf
 Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE
 DUTCH ACCREDITATION
 COUNCIL



SPECIFICATION OF THE CERTIFIED PRODUCT**Product data**

Product	: TERMINAL BLOCKS
Trade name(s)	: PHOENIX CONTACT
Type(s)/model(s)	: URTK/S, URTK/S-BEN, URTK/S-BEN BU and URTK/SP
Material	: thermoplastic material
Mounting	: top hat rail 35 mm and G-profile rail 32 mm

Product data – type URTK/S

Rated voltage	: 400 V
Rated cross section	: 6 mm ²
Rated connecting capacity	: one conductor 0,5 - 10 mm ² solid 0,5 - 6 mm ² flexible without ferrule 0,5 - 10 mm ² flexible with ferrule two conductors 0,5 - 2,5 mm ² solid 0,5 - 6 mm ² flexible without ferrule 0,5 - 4 mm ² flexible with ferrule
Rated impulse withstand voltage	: 6 kV
Torque	: 1,2 - 1,5 Nm screw type clamping unit 0,5 - 0,8 Nm disconnecter
Description	: disconnect terminal block with 2 screw-type clamping units, 1-pole

Product data – type URTK/S-BEN

Rated voltage	: 500 V
Rated cross section	: 6 mm ²
Connecting capacity	: one conductor 0,5 - 10 mm ² solid 0,5 - 6 mm ² flexible without ferrule 0,5 - 10 mm ² flexible with ferrule two conductors 0,5 - 2,5 mm ² solid 0,5 - 6 mm ² flexible without ferrule 0,5 - 4 mm ² flexible with ferrule
Rated impulse withstand voltage	: 6 kV
Torque	: 1,5 - 1,8 Nm screw clamping unit 0,6 - 0,8 Nm disconnecter
Description	: disconnect terminal block with 2 screw-type clamping units, 1-pole

Product data – type URTK/S-BEN BU

Rated voltage	: 500 V
Rated connection capacity	: 6 mm ²
Connectable conductors	: one conductor 0,5 - 10 mm ² solid 0,5 - 6 mm ² flexible without ferrule 0,5 - 10 mm ² flexible with ferrule two conductors 0,5 - 2,5 mm ² solid 0,5 - 6 mm ² flexible without ferrule 0,5 - 4 mm ² flexible with ferrule
Rated impulse withstand voltage	: 6 kV

Description : disconnect terminal block with 2 screw-type clamping units, 1-pole

Product data – type URTK/SP

Rated voltage : 500 V
Rated cross section : 6 mm²
Rated connecting capacity : one conductor
0,5 - 10 mm² solid
0,5 - 6 mm² flexible without ferrule
0,5 - 6 mm² flexible with ferrule
two conductors
0,5 - 2,5 mm² solid
0,5 - 4 mm² flexible without ferrule
0,5 - 2,5 mm² flexible with ferrule
Rated impulse withstand voltage : 6 kV
Torque : 1,5 - 1,8 Nm clamping unit
0,6 - 0,8 Nm disconnecter
Description : disconnect terminal block with 2 screw-type clamping units, 1-pole

TESTS**Test requirements**

EN 60947-7-1:2009

Test result

The test results are laid down in DEKRA test file 222084500.

Additional information

This certificate replaces certificate No. 2191240.01 which we herewith declare invalid.

Conclusion

The examination proved that all requirements were met.

Factory locations

The factory location is registered with numbers 296864, 309513, 32170, 326192 and 33937.