

CERTIFICATE

Issued to:
Applicant:
Phoenix Contact GmbH & Co. KG
Flachsmarktstrasse 8
32825 Blomberg, Germany

Licensee:
Phoenix Contact GmbH & Co. KG
Flachsmarktstrasse 8
32825 Blomberg, Germany

Product : Terminal block for copper conductors
Trade name(s) : Phoenix Contact
Type(s)/model(s) : UK 16 N, UK 2,5 N and UK 5 N

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard(s) EN 60947-7-1:2009
- an inspection of the factory location according to CENELEC Operational Document CIG 021
- a DEKRA certification agreement with the number 900469


DEKRA hereby grants the right to use the KEMA-KEUR certification mark.

The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration and under the conditions of the KEMA-KEUR certification agreement.

This certificate is issued on 6 January 2023 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 71-125614

DEKRA Certification B.V.



B.T.M. Holtus
Managing Director



JMG Marggraf
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE
DUTCH ACCREDITATION
COUNCIL



SPECIFICATION OF THE CERTIFIED PRODUCT**Product data**

Product	: Terminal block for copper conductors
Trade name(s)	: Phoenix Contact
Type(s)/model(s)	: UK 16 N, UK 2,5 N and UK 5 N
Rated insulation voltage	: 800 V
Rated insulation voltage	: 8 kV
Material	: thermoplastic material
Description	: terminal blocks with screw-type terminals, for mounting on top hat rail 35 mm and G-profile 32 mm

Product data – type UK 16 N

Rated connection capacity	: 16 mm ²
Connectable conductors	: one conductor 2,5 - 25 mm ² rigid 4,0 - 16 mm ² flexible without ferrule 1,5 - 16 mm ² flexible with ferrule two conductors 1,5 - 6 mm ² rigid 1,5 - 4 mm ² flexible without ferrule 1,5 - 6 mm ² flexible with ferrule

Product data – type UK 2,5 N

Rated connection capacity	: 2,5 mm ²
Connectable conductors	: one conductor 0,2 - 4 mm ² rigid 0,2 - 2,5 mm ² flexible without ferrule 0,25 - 2,5 mm ² flexible with ferrule two conductors 0,2 - 1 mm ² rigid 0,2 - 1 mm ² flexible without ferrule 0,25 - 1 mm ² flexible with ferrule

Product data – type UK 5 N

Rated connection capacity	: 4 mm ²
Connectable conductors	: one conductor 0,2 - 6 mm ² rigid 0,2 - 4 mm ² flexible without ferrule 0,25 - 4 mm ² flexible with ferrule two conductors 0,2 - 1,5 mm ² rigid 0,2 - 1,5 mm ² flexible without ferrule 0,25 - 1,5 mm ² flexible with ferrule

TESTS**Test requirements**

EN 60947-7-1:2009

Test result

The test results are laid down in DEKRA test file 224568300.

Additional information

This certificate replaces certificate No. 71-113414 which we hereby declare invalid.

Conclusion

The examination proved that all requirements were met.

Factory locations

The factory locations are registered with the numbers 676000, 306086, 330626, 296866, 296864, 326192, 32170, 33937, 36852 and 55519.