



Certificate of Compliance

Certificate: 2450352

Master Contract: 158887

Project: 2450352

Date Issued: November 18, 2011

Issued to: Phoenix Contact Inc.

P.O. Box 4100
Harrisburg, PA 17111-0100
USA
Attention: Brian Fleming

The products listed below are eligible to bear the CSA Mark shown



Minoru Morimoto

Issued by: Minoru Morimoto, C.E.T.

PRODUCTS

CLASS 6228 01 - WIRE CONNECTING DEVICES - Terminal Assemblies

Terminal blocks, DIN rail mount, for use with solid and stranded copper insulated wire as follows:

Type	Wire Range AWG	Torque (Lb-in)	Max Amps	Max Volts	Group	Notes
VBST 4-FS(6-2,8-0,8)ST4	30-10	5 - 7	20/5	300/600	B,C/D	1, 2
VBSTB 4-FS(6-2,8-0,8)	30-10	5 - 7	20/5	300/600	B,C/D	1, 2

Notes:

1. Terminal block with screw tightening pressure wire connector and quick-connect male tabs.
2. Spacing group designation "D" for industrial devices having limited rating 5A max, 600V max
3. These products are certified only for supply to manufacturers for the assembly as components of equipment where the suitability of the combination is determined by CSA International.



Certificate: 2450352

Master Contract: 158887

Project: 2450352

Date Issued: November 18, 2011

APPLICABLE REQUIREMENTS

CSA Standard C22.2 No. 158 - Terminal Blocks