



Certificate of Compliance

Certificate: 2655028 **Master Contract:** 158887
Project: 80101747 **Date Issued:** 09/15/2022
Issued to: PHOENIX CONTACT GmbH & Co. KG
Flachmarkstraße 8
Blomberg, North Rhine-Westphalia D-32825
Germany
Attention: Jyoti Malyan

The products listed below are eligible to bear the CSA Mark shown



Issued by: Manikandan N
Manikandan N

PRODUCTS

C622801 WIRE CONNECTING DEVICES - Terminal Assemblies

Terminal block fuse holder (Fuse plug for terminal blocks Cat No UK4-TG):

Models
Cat Nos ST-SI-UK4, ST-SILED (with suffixes), ST-SILED-UK4 120kOhm and ST-SILA (with suffixes), rated 10A, 300V, for use with 5mm by 20 mm miniature cartridge fuse.

Terminal block fuse holder (Fuse plug for terminal blocks type -TG):

Models
Cat Nos P-FU 5x20 LED 24 120kOhm, P-FU 5x20 LED 24-5 120kOhm, rated 10A, 300V, for use with 5mm by 20 mm miniature cartridge fuse.

Notes:

1. These products are certified only for supply to manufacturers, as component, for the assembly of equipment, where the suitability and acceptability of the combination is to be determined in the end use.



Certificate: 2655028

Master Contract: 158887

Project: 80101747

Date Issued: 09/15/2022

-
2. Cat No P-FU is for use with terminal blocks type -TG, except Cat No UK4-TG.
 3. Cat Nos ST-SI, ST-SILED, ST-SILA are for use with terminal block Cat No UK4-TG only.



Certificate: 2655028

Project: 80101747

Master Contract: 158887

Date Issued: 09/15/2022

APPLICABLE REQUIREMENTS

CSA C22.2 No. 158:10 (R2019) - Terminal Blocks



Certificate: 2655028


Project: 80101747

Master Contract: 158887

Date Issued: 09/15/2022

Notes:

Products certified under Class C622801 have been certified under CSA's ISO/IEC 17065 accreditation with the Standards Council of Canada (SCC). www.scc.ca





Supplement to Certificate of Compliance

Certificate: 2655028

Master Contract: 158887

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
80101747	September 15, 2022	Update to report no. 2655028 to comply with CSA Std C22.2 No. 158-10 as per Certification Notice Wiring Devices No. 77.
2655028	October 16, 2013	Add terminal block fuseholder (Fuse plug), Cat Nos P-FU, ST-SILED.
LR 13631-175	June 13, 1991	Add terminal block fuseholder, Cat No ST-SILED and Cat No ST-SILA.
LR 13631-119	June 05, 1990	Terminal block fuseholder Cat No ST-SI-UK4 for use with terminal block UK4-TG.