



Certificate of Compliance

Certificate: 70051965 **Master Contract:** 158887
Project: 80233678 **Date Issued:** 2024-12-05
Issued to: PHOENIX CONTACT GmbH & Co. KG
Flachsmarkstraße 8
Blomberg, North Rhine-Westphalia D-32825
Germany
Attention: Renu Goyat

The products listed below are eligible to bear the CSA Mark shown



Issued by: Sindhu HC
Sindhu H C

PRODUCTS

Class 6228 01 WIRE CONNECTING DEVICES - Terminal Assemblies

Terminal blocks, for copper wire, for use with FAME Modular Test System as follows:

Model(s)	Wire Size (AWG)	Tightening Torque (N · m)	Voltage (V)	Current (A max)	Use Group
UTWE 6	24-8	1.5-1.8	600	30	B/C
	24-8	1.5-1.8	600	5	D
UTWE 6-2	24-8	1.5-1.8	600	30	B/C
	24-8	1.5-1.8	300	5	D
UTRE 6-2	24-8	1.5-1.8	600	30	B/C
PTWE 6-2	20-8	-	300	20	B/C
	20-8	-	600	5	D
PTRE 6-2	20-8	-	600	20	B/C
RSCWE 6-3/X	20-8	1.5-1.8	600	31	B/C



Certificate: 70051965

Master Contract: 158887

Project: 80233678

Date Issued: 2024-12-05

	20-8	1.5-1.8	600	5	D
	20-8	1.5-1.8	300	10	D
	20-8	1.5-1.8	150	15	D
RSCWE 6-3/X AUX	20-8	1.5-1.8	600	31	B/C
	20-8	1.5-1.8	600	5	D
	20-8	1.5-1.8	300	10	D
	20-8	1.5-1.8	150	15	D
RSCWE 6-3/2 SL	20-8	1.5-1.8	600	31	B/C
BTFE 6-3/X, BTFE 6-3/X nU, BTFE 6-3/X AUX, BTFE 6-3/x nU AUX	20-10	1-1.3	300	30	B/C
	20-10	1-1.3	600	5	D
	20-10	1-1.3	300	10	D
	20-10	1-1.3	150	15	D
FTP- 3F/x, FTP-3F/x nU	-	-	600	5	D
	-	-	300	10	D
	-	-	150	15	D
FBP-3F/x, FBP-3F/x nU AUX, FBP-3F/x AUX, FBP-3F nU, FBP-3F/x nU	-	-	-	-	-
FTP, FTP-2 S, FTP-2 M, FTP-2 L	-	-	600	31*	B, C
FTP n + 1, FTPC n + 1	-	-	300	10	D
	-	-	600	5	D
FTPR-2/n, FTP-2/n	-	-	300	31*	B, C
	-	-	600	5	D
FTPC-3/nS, FTPR-3/nS	-	-	300	31*	B, C
	-	-	600	5	D

*-Maximum current rating of test plug, can vary according to mating/basic article rating during the time of application.

Note: Series model may be followed by alpha-numeric suffixes denoting combination of elements, installation, wire size, function, and/or number of poles.

APPLICABLE REQUIREMENTS

CSA C22.2 No. 158-23 (Fourth Edition) - Terminal blocks



Certificate: 70051965


Project: 80233678

Master Contract: 158887

Date Issued: 2024-12-05

Notes:

Products certified under Class(es) C622801 have been certified under CSA's ISO/IEC 17065 accreditation with the Standards Council of Canada (SCC). www.scc.ca





Supplement to Certificate of Compliance

Certificate: 70051965

Master Contract: 158887

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
80233678	2024-12-05	Update for Report 70051965 to add new series of FTP article and to update electrical rating of UTWE 6 and PTWE 6 series articles.
80184435	2023-10-27	Update Report 70051965 to add alternate material for pusher - Durethan AKV30FN04+(f2).
80077962	2021-05-27	Update to report 70051965 to add alternate material for Pusher.
80055796	2020-12-24	Update to report no. 70051965 to add Cat. Nos. RSCWE 6-3/X AUX, BTFE 6-3/X, BTFE 6-3/X nU, BTFE 6-3/X AUX, BTFE 6-3/x nU AUX, FTP- 3F/x, FTP-3F/x nU, FBP-3F/x, FBP-3F/x nU AUX, FBP-3F/x AUX, FBP-3F nU, FBP-3F/x nU for use in FAME 3 Modular Test System.
70191252	2018-08-09	Add FAME 3-RSCWE 6-3/2SL + FTP-3/2SL
70066167	2016-03-02	Add Cat Nos UTWE 6, UTWE 6-2, UTRE 6-2, PTWE 6-2, PTRE 6-2.
70051965	2016-02-02	Terminal Blocks, Cat No RSCWE 6-3.