

Certificate



Cyber Security

www.tuv.com
ID 0600000000

No.: 968/CSP 1037.00/25

Product tested	PLCnext Control	Certificate holder	Phoenix Contact GmbH & Co. KG Flachmarktstr. 8 32825 Blomberg Germany
Type designation	AXC F 1152, AXC F 2152, AXC F 3152, AXC F XT SPLC 1000, RFC 4072S, NFC 482S, BPC 9102S		
Codes and standards	IEC 62443-4-1:2018 (Edition 1.0) IEC 62443-4-2:2019 (Edition 1.0)		
Intended application	The PLCnext Control complies with the requirements according to IEC 62443-4-1 and Security Level Capability 2 (SL-C 2) according to IEC 62443-4-2.		
Specific requirements	The PLCnext Control is only valid in the dedicated security context as documented in the user manuals. The instructions of the associated user manuals released by manufacturer must be considered. The current versions of the product are specified in the currently valid Revision List. The Revision List is released by the manufacturer in cooperation with the certification body.		

The issue of this certificate is based upon an examination, whose results are documented in Report No. 968/CSP 1037.00/25 dated 2025-07-04.

This certificate is valid only for products which are identical with the product tested.

TÜV Rheinland Industrie Service GmbH
Bereich Automation
Funktionale Sicherheit
Am Grauen Stein, 51105 Köln

Köln, 2025-07-04

Certification Body Safety & Security for Automation & Grid

Dipl.-Ing. (FH) Sergei Biberdorf

www.fs-products.com
www.tuv.com



Type Designation	Description	HW Revision	FW Revision	Report-No.:	Certification Status
AXC F 1152	PLCnext Control small controller	1151412	2024.0.x LTS	968/CSP 1037.00/25	<i>Valid</i>
AXC F 2152	PLCnext Control mid-size controller	2404267	2024.0.x LTS	968/CSP 1037.00/25	<i>Valid</i>
AXC F XT ETH 1TX	Extension module second independent ETH interface for AXC F 2152	2403115	.I.	968/CSP 1037.00/25	<i>Valid</i>
AXC F 3152	PCLnext Control hig-end controller	1069208	2024.0.x LTS	968/CSP 1037.00/25	<i>Valid</i>
AXC F XT SPLC1000	Extension module for Safety-oriented control for operating PROFIsafe® devices for AXC F 2152 and 3152	1159811	01.01.0000	968/CSP 1037.00/25	<i>Valid</i>
RFC 4072S	PLCnext Control for safety-related operation	1051328	2024.0.x LTS	968/CSP 1037.00/25	<i>Valid</i>
NFC 482S	PLCnext Control for safety-related operation Customer specific Hardware	1050841	2024.0.x LTS	968/CSP 1037.00/25	<i>Valid</i>
BPC 9102S	Industrial box PC with integrated safety-related controller	1246285	2024.0.x LTS	968/CSP 1037.00/25	<i>Valid</i>

The content of this Revision List has been agreed between Manufacturer and Certification Body.

Revision:

Date	Rev.	Description / Changes	Author
2025-07-03	1.0	Initial creation, based on Report-No.: 968/CSP 1037.00/25	Ti/A-FS&CS