



Certificate of Compliance

Certificate: 2615953 **Master Contract:** 158887
Project: 80160341 **Date Issued:** 03/28/2023
Issued to: PHOENIX CONTACT GmbH & Co. KG
Flachmarkstraße 8
Blomberg, North Rhine-Westphalia D-32825
Germany
Attention: Renu Goyat

The products listed below are eligible to bear the CSA Mark shown



Issued by: Manikandan N
Manikandan N

PRODUCTS

C622801 WIRE CONNECTING DEVICES - Terminal Assemblies

Terminal blocks for solid and stranded copper insulated conductor as follows:

Models	Wire Range (AWG)	Torque (N · m)	Current (A)	Voltage (V)	Use Group	Notes
MUT 1.5	26-16 (str)	0.22-0.25	10/10	300/300	B/D	1,2,3
	26-14 (sol)	0.22-0.25	15/10	300/300	B/D	1,2,3
MUT 1.5-PE	26-16 (str)	0.22-0.25	---	---	B,D	1,2
	26-14 (sol)	0.22-0.25	---	---	B,D	1,2
MUT 2.5	26-12	0.5	20	300/600	B,C/D	1,2,3
MUT 2.5-PE	26-12	0.5	---	---	B,C,D	1,2
MUTTB 2.5	24-12	0.5-0.6	20/10	150/300	B,C/D	1,2,3
MUTTB 2.5-PV	24-12	0.5-0.6	20/10	150/300	B,C/D	1,2,3
MUTTB 2.5-BE	24-12	0.5-0.6	20/10	150/300	B,C/D	1,2,3
MUTTB 2.5-DIO/O-U	24-12	0.5-0.6	0.5	150/300	B,C/D	1,2,3



Certificate: 2615953

Master Contract: 158887

Project: 80160341

Date Issued: 03/28/2023

MUTTB 2.5-DIO/U-O	24-12	0.5-0.6	0.5	150/300	B,C/D	1,2,3
MUTTB 2.5-2DIO/O-UL/O-UR	24-12	0.5-0.6	0.5	150/300	B,C/D	1,2,3
MUT 4	26-10	0.6	30	300/600	B,C/D	1,2,3
MUT 4-PE	26-10	0.6	---	---	B,C,D	1,2
MUT 6	24-8	0.5-0.6	30/10	300/300	B,C/D	1,2,3
MUT 6-PE	24-8	0.5-0.6	---	---	B,C,D	1,2

Notes:

1. These products are certified only for supply to manufacturers for the assembly, as component of equipment where the suitability of the combination is to be determined in the end use.
2. Not intended for use at higher than 40°C ambient temperature.
3. Spacing group designation "D" for industrial devices having limited rating 5A max, 600V max.



Certificate: 2615953

Project: 80160341

Master Contract: 158887

Date Issued: 03/28/2023

APPLICABLE REQUIREMENTS

CSA C22.2 No. 158:10 (R2019) - Terminal Blocks



Certificate: 2615953


Project: 80160341

Master Contract: 158887

Date Issued: 03/28/2023

Notes:

Products certified under Class C622801 have been certified under CSA's ISO/IEC 17065 accreditation with the Standards Council of Canada (SCC). www.scc.ca





Supplement to Certificate of Compliance

Certificate: 2615953

Master Contract: 158887

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
80160341	March 28, 2023	Update to Report 2615953 to add MUTTB 2.5 series terminal blocks.
80114647	April 11, 2022	Update to report 2615953 to add Cat. Nos. MUT 1.5, MUT 1.5-PE, MUT 6, MUT 6-PE and to add alternate materials.
2615953	April 25, 2013	Terminal Blocks, Cat Nos MUT 2.5, MUT 4, MUT 2.5-PE, MUT 4-PE. Class 6228 01, C22.2 No. 158-10.