



Certificate of Compliance

Certificate: 80174529 **Master Contract:** 158887
Project: 80195351 **Date Issued:** 2024-03-22
Issued to: PHOENIX CONTACT GmbH & Co. KG
Flachsmarkstraße 8
Blomberg, North Rhine-Westphalia D-32825
Germany
Attention: Renu Goyat

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



Issued by: Sindhu H C
Sindhu H C

PRODUCTS

C622801 WIRE CONNECTING DEVICES - Terminal Assemblies
C622881 WIRE CONNECTING DEVICES - Terminal Assemblies - Certified to US Standards

Test plugs for terminal blocks intended to use with solid and stranded copper insulated wire as follows:

Model(s)	Wire Range (AWG)	Torque (Lb-in)	Wire Type	Voltage (V)	Current (A)	Use Group
LP 2.5/n	26-12	--	Cu	600/600/800	20/5/20	B, C/D/F
LP 2.5/ 1-L	26-12	--	Cu	600/600/800	20/5/20	B, C/D/F
LP 2.5/ 1-M	26-12	--	Cu	600/600/800	20/5/20	B, C/D/F
LP 2.5/ 1-R	26-12	--	Cu	600/600/800	20/5/20	B, C/D/F
LPO 2.5	26-12	--	Cu	600/600/800	20/5/20	B, C/D/F
LPO 2.5/E	26-12	--	Cu	600/600/800	20/5/20	B, C/D/F
LPO 4	26-12	--	Cu	600/600/800	20/5/20	B, C/D/F



Certificate: 80174529

Master Contract: 158887

Project: 80195351

Date Issued: 2024-03-22

LPO 4/E	26-12	--	Cu	600/600/800	20/5/20	B, C/D/F
LPO 6	26-12	--	Cu	600/600/800	20/5/20	B, C/D/F
LPO 6/E	26-12	--	Cu	600/600/800	20/5/20	B, C/D/F
LPO 10	26-12	--	Cu	600/600/800	20/5/20	B, C/D/F
LPO 10/E	26-12	--	Cu	600/600/800	20/5/20	B, C/D/F
LPO 16	26-12	--	Cu	600/600/800	20/5/20	B, C/D/F
LPO 16/E	26-12	--	Cu	600/600/800	20/5/20	B, C/D/F
LPO 35	26-12	--	Cu	600/600/800	20/5/20	B, C/D/F
LPO 35/E	26-12	--	Cu	600/600/800	20/5/20	B, C/D/F

Notes:

1. Supplied only to manufacturers, as components, for the assembly of electrical equipment where the suitability of the combination is determined in the end use by CSA.
2. The usage group F is applicable only for the class no. 6228 81.

APPLICABLE REQUIREMENTS

UL 1059 5th edition June 9, 2021 - Terminal Blocks for Electrical Circuits

CSA C22.2 No. 158-23 (Fourth Edition) - Terminal blocks



Certificate: 80174529


Project: 80195351

Master Contract: 158887

Date Issued: 2024-03-22

Notes:

Products certified under Class(es) C622801 have been certified under CSA's ISO/IEC 17065 accreditation with the Standards Council of Canada (SCC). www.scc.ca





Supplement to Certificate of Compliance

Certificate: 80174529

Master Contract: 158887

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
80195351	2024-03-22	Update for Report 80174529 to add LPO 10, LPO10/E, LPS 16, LPO16/E, LPO 35 and LPO 35/E test plugs for terminal blocks.
80174529	2023-08-25	Original cCSAus Certification of LP and LPO series test plugs for terminal blocks.