

CERTIFICATE OF COMPLIANCE

Certificate Number 20171201-E192998
Report Reference E192998-20170509
Issue Date 2017-DECEMBER-01

Issued to: PHOENIX CONTACT GMBH & CO KG
FLACHSMARKTSTRASSE 8
32825 BLOMBERG GERMANY

**This is to certify that
representative samples of** COMPONENT - TERMINAL BLOCKS FOR USE IN CLASS
I, ZONE 0, 1 AND 2 HAZARDOUS LOCATIONS
Please see addendum

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: Please see addendum
Additional Information: See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's
Certification and Follow-Up Service.

The UL Recognized Component Mark generally consists of the manufacturer's identification and catalog
number, model number or other product designation as specified under "Marking" for the particular
Recognition as published in the appropriate UL Directory. As a supplementary means of identifying products
that have been produced under UL's Component Recognition Program, UL's Recognized Component Mark:
, may be used in conjunction with the required Recognized Marks. The Recognized Component Mark is
required when specified in the UL Directory preceding the recognitions or under "Markings" for the individual
recognitions.

Recognized components are incomplete in certain constructional features or restricted in performance
capabilities and are intended for use as components of complete equipment submitted for investigation rather
than for direct separate installation in the field. The final acceptance of the component is dependent upon its
installation and use in complete equipment submitted to UL LLC.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number 20171201-E192998
Report Reference E192998-20170509
Issue Date 2017-DECEMBER-01

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Terminal Blocks, Class I, Zone 1, AEx eb IIC Gb; Ex eb IIC Gb

Type UT with suffixes 2.5, 2.5-PE, 2.5-QUATTRO, 2.5-QUATTRO-PE, 2.5-TWIN, 2.5-TWIN-PE, 4, 4-PE, 4-MTD, 4-MTD-PE, 4-MTD-PE/S, 4-QUATTRO, 4-QUATTRO-PE, 4-TWIN, 4-TWIN-PE, 6, 6-PE, 10, 10-PE, 16, 16-PE, 35, 35-IB, 35-PE, 35-PE-IB.

Type UTTB with suffixes 2.5, 2.5-PE, 2.5-PV, 4, 4-PE, or 4-PV.

Type AGK4 with suffixes –UT10, –UT16, or –UT35.

UL 60079-0, Explosive atmospheres – Part 0: Equipment – General requirements

UL 60079-7, Explosive Atmospheres – Part 7: Equipment protection by increased safety “e”

CAN/CSA C22.2 No. 60079-0:15, Explosive atmospheres — Part 0: Equipment — General requirements

CAN/CSA C22.2 No. 60079-7:16, Explosive atmospheres — Part 7: Equipment protection by increased



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

