



CERTIFICATION REPORT

178 Rexdale Blvd., Rexdale (Toronto), Ontario M9W 1R3

MASTER REPORT NO: LR 13631-197

Edition 1: October 29, 1991; Application No LR 13631-197 - Rexdale
Issued by P. Johnson, C.E.T., Reviewed by D. Hay, P. Eng.

Contents: Pages - 1 to 5
Figure - Fig 1

SUBJECT

CLASS 6228 01 - WIRE CONNECTING DEVICES - Terminal Assemblies

Terminal blocks, Cat Nos DFK 4-PE, grounding type, for use with Nos 26 to 10 AWG copper wire.

Note: These terminal blocks are Certified, as components, for use only in Certified equipment where the suitability of the combination is determined by the Canadian Standards Association.