



Certificate of Compliance

Certificate: 2585951

Master Contract: 158887

Project: 80018650

Date Issued: 2019-10-22

Issued To: Phoenix Contact GmbH & Co. KG
Flachsmarktstrasse 8
Blomberg, Nordrhein-Westfalen, D-32825
Germany

Attention: Reiner Hoerding

The products listed below are eligible to bear the CSA Mark shown

Issued by: Johann Borabon
Johann Borabon



PRODUCTS

CLASS 6228 01 - WIRE CONNECTING DEVICES Terminal Assemblies

Terminal blocks:

Cat Nos MSTBV 1.5(2.5)/X, MSTBH 1.5(2.5)/X, MSTBP 1.5(2.5)/X, MSTBVA 1.5(2.5)/X, MSTBHK 1.5/X, GMSTB 1.5(2.5)/X, GMSTBA 1.5(2.5)/X, GMSTBV 1.5(2.5)/X-X, GMSTBVA 1.5(2.5)/X, GMSTBHK 1.5(2.5)/X, , SMSTBA 1.5(2.5)/X, UMSTBHK 1.5(2.5)/X, rated 10A, 300V, 5 lb-in torque, for Nos 12-28 AWG solid or stranded copper conductors.

Cat No GMSTBP 2.5/X-ST-7.62, MSTBP 1.5(2.5)/X-ST(-5.08), MSTBT 1.5(2.5)/X-ST(5.08), MSTBTP 2.5/X-ST(-5.08), rated 10A, 300V, 5 lb-in torque, for Nos 12-28 AWG solid or stranded copper conductors.

Cat No MSTBV 2.5/X-G(-5.08), MSTBV 2.5/X-GF(-5.08), MSTBV 2.5/X-GEH-5.08, MSTBVA 2.5/X-G(-5.08), rated 12A, 300V, for Nos 12-28 AWG solid or stranded copper conductors.



Certificate: 258595180018650
Project: 80018650

Master Contract: 158887
Date Issued: 2019-10-22

Cat Nos MSTB 2.5/X-G(-5.08)(-LA), MSTBA 2.5/X-G(-5.08)(-LA), SMSTB 2.5/X-ST(-5.08) rated 15A, 300V, 5 lb-in torque, for Nos 12-28 AWG solid or stranded copper conductors.
Terminal block headers Cat Nos MSTBW 2.5/X-G(-5.08), SMSTB 2.5/X-G(-5.08), SMSTBA 2.5/X-G(-5.08), rated 15A, 300V.

Note: Cat Nos MSTBV 1.5(2.5)/X, MSTBH 1.5(2.5)/X, MSTBP 1.5(2.5)/X, MSTBVA 1.5(2.5)/X, MSTBHK 1.5/X, GMSTB 1.5(2.5)/X, GMSTBA 1.5(2.5)/X, GMSTBV 1.5(2.5)/X-X, GMSTBVA 1.5(2.5)/X, GMSTBHK 1.5(2.5)/X, , SMSTBA 1.5(2.5)/X, UMSTBHK 1.5(2.5)/X have suffixes "-G, -GF, -LA, -R, -ST, -STF,-5.08,-7.62".

APPLICABLE REQUIREMENTS

CSA Std. C22.2 No. 158-10 - Terminal Blocks