

178 Rexdale Blvd., Rexdale (Toronto), Ontario M9W 1R3

REPORT NO: LR 13631-85

Edition 1: September 30, 1988; Application No LR 13631-85 - Rexdale
Issued by V. O'Connor, C.E.T.

Contents: Pages - 1 to 4.

SUBJECT

CLASS 6228 01 - WIRE CONNECTING DEVICES - Terminal Assemblies

Terminal blocks for use with CSA Certified solid or stranded copper conductors, Cat Nos GMKDS1.5/X, rated 10A, 300V, 5 lb-in torque for Nos 22-14 AWG conductors; GMKDS1.5/X-7.62, rated 10A, 300V, 5 lbs-in torque for Nos 22-14 AWG conductors; KDS2.5, rated 10A, 300V, 5 lbs-in torque for Nos 24-12 AWG conductors; KDS 4, rated 30A, 300V, 5 lbs-in torque for Nos 22-10 AWG conductors; UKK 5-MTK-P/P, rated 15A, 300V, 5 lbs-in torque for Nos 22-12 AWG conductors.

Notes:

1. For Cat Nos GMKDS(-7.62), the letter "X" represents either numbers 2 or 3 to denote positions.
2. Certified as a component of CSA Certified equipment.