



Certificate of Compliance

Certificate: 2585984 **Master Contract:** 158887
Project: 80112693 **Date Issued:** 03/16/2023
Issued to: PHOENIX CONTACT GmbH & Co. KG
Flachsmarkstraße 8
Blomberg, North Rhine-Westphalia D-32825
Germany
Attention: Oliver Pethig

The products listed below are eligible to bear the CSA Mark shown



Issued by: Manikandan N
Manikandan N

PRODUCTS

C622801 WIRE CONNECTING DEVICES - Terminal Assemblies

Terminal block and terminal block headers for solid or stranded copper conductors:

Models	Wire Size (AWG)	Torque (N·m)	Voltage (V)	Current (A)	Use Group
MSTB 2.5/X-STZ (-5.08)	12-28	0.5-0.6	300	15/10	B/D
DFK-MSTB 2.5/X-G(-5.08)	-	-	300	15/10	B/D
DFK-MSTB 2.5/X-GF (-5.08)	-	-	300	15/10	B/D



Certificate: 2585984

Project: 80112693

Master Contract: 158887

Date Issued: 03/16/2023

APPLICABLE REQUIREMENTS

CSA C22.2 No. 158:10 (R2019) - Terminal Blocks



Certificate: 2585984

Project: 80112693

Master Contract: 158887

Date Issued: 03/16/2023

Notes:

Products certified under Class C622801 have been certified under CSA's ISO/IEC 17065 accreditation with the Standards Council of Canada (SCC). www.scc.ca

