



CERTIFICATION REPORT

REPORT NO: LR 13631-38

178 Rexdale Blvd., Rexdale (Toronto), Ontario M9W 1R3

Edition 1: October 3, 1986; Application No LR 13631-38 - Rexdale
Issued by D. Hay, P. Eng.

Edition 2: June 17, 1991; Application No LR 13631-173 - Rexdale
Issued by D. Hay, P. Eng.

Pages Replaced: Report Reissued

Contents: Pages - 1 to 4

SUBJECT

CLASS 6228 01 - WIRE CONNECTING DEVICES - Terminal Assemblies

Terminal blocks, Front 1.5 series; 300V, 10A; for use with No 14 to 22 AWG solid or stranded wire; Front 2.5, 300V, 10A for use with Nos 24 to 12 AWG solid or stranded wire.

Note: Certified as a component of Certified electrical equipment.